

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 of 4	
2. AMENDMENT/MODIFICATION NO. Amendment 07		3. EFFECTIVE DATE 5/09/11		4. REQUISITION/PURCHASE NO. 4200374438		5. PROJECT NO. (If applicable) 98814&98815	
6. ISSUED BY JOHN F. KENNEDY SPACE CENTER, NASA PROCUREMENT OFFICE, CODE: OP-CS-A/Gary.M.Felker Jr. KENNEDY SPACE CENTER, FL 32899				7. ADMINISTERED BY (If other than Item 6) JOHN F. KENNEDY SPACE CENTER, NASA PROCUREMENT OFFICE, CODE: OP-CS-B KENNEDY SPACE CENTER, FL 32899			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and Zip Code)				<input checked="" type="checkbox"/>			
				9A. AMENDMENT OF SOLICITATION NO. NNK11374438R			
				9B. DATED (SEE ITEM 11) 3/28/11			
				10A. MODIFICATION OF CONTRACT/ORDER NO.			
CODE				KRED CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required) N/A							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
<input type="checkbox"/>	A	THIS CHANGE ORDER IS ISSUED PURSUANT TO (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
<input type="checkbox"/>	B	THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (Such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
<input type="checkbox"/>	C	THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
<input type="checkbox"/>	D	OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return <u> </u> copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment 07 is to provide responses to bidder questions and make changes to the solicitation as a result of the Government's responses to the questions.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Gary.M.Felker Jr.			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
BY _____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)			

1. The Government's responses to questions received from potential offerors are provided as Attachment 1 to this amendment.
2. The following changes are made to the solicitation as a result of the Government's responses to bidder questions.

SECTION C, DESCRIPTION/SPECIFICATION/STATEMENT OF WORK:

Article C.2, Contract Drawings, Maps, and Specifications, paragraph (b) Addenda to Specifications and Drawings, is revised to include changes as a result of the Government's responses to questions submitted. Below is a description of the changes made to Article C.2(b) of the solicitation.

Drawing 79K38699 Rev B Drawing Sheet C55, Detail 2, is revised to state: "Valmatic 1800 series check valves or engineered approved equal".

Drawing 79K38699 Rev B, Drawing Sheet C44, Detail 35, callout 4" X 3" RED and 4" PVC WM are revised to 3" X 2" RED and 2" PVC WM.

Drawing 79K38699 Rev B, Drawing Sheet C51, Detail 3, delete the following callouts in their entirety "Socket clamp Anvil International, Figure 594 (typ); Anchor strap Anvil International, Figure 592". Add Detail Notes 1 and 2 as follows: "1) Restrained plugs for PVC pipe materials shall conform to Socket clamp Anvil International, Figure 594, or approved equal (typ)". "2) If a restrained plug is not beside a MJ fitting, the Contractor can install a restrained cap. Restrained mechanical joint ductile iron plugs and caps shall conform to ANSI/AWWA C153/A21.53".

Drawing 79K38699 Rev B, Drawing Sheet C3, Note 1 is changed from "Jack and bore with 16" steel casing pipe and 10" DI carrier pipe" to "Jack and bore with 24" steel casing pipe and 10" DI carrier pipe".

Drawing 79K38703 Rev B, Drawing Sheet C25 Detail 1, is revised to replace the following upper manhole size to 2' - 0".

Drawing 79K38703 Rev B, Drawing Sheet M11, Lift Station Data Table, insert an additional row "LS12a" for "Discharge Pipe Material – PVC".

Specification 79K38700 Rev B, Section 27 13 23.00, Part 2.1.3.7 is replaced in its entirety and is to read as follows:

2.1.3.7 Number of Fibers Per Tube Per Cable

12-fiber cable shall contain single mode fibers. Cable core configuration shall be comprised of two loose buffer tubes, each containing six fibers. Six fibers in each loose buffer tube shall be color coded using the first colors of the standard Munsell color code, Blue, Orange, Green, Brown, Slate, and White. Loose buffer tubes shall be color coded using the standard Munsell color code, Blue, Orange, Green, Brown and Slate. Consider single mode fibers last in configuration.

3. A conformed copy of Sections B through M of the solicitation is provided as Attachment 2 to this amendment.
5. **Below is a list of the attachments provided as a result of Amendment 7:**
Attachment 1: The Government's responses to questions received from potential offerors
Attachment 2: Conformed copy of Sections B through M of the solicitation which includes the changes resulting from this Amendment 07.
6. All other terms and conditions of the solicitation remain unchanged.